

# TYPE APPROVAL CERTIFICATE

**This is to certify:****That the Peripheral Equipment**

with type designation(s)  
**CIO 116, CIO 208, CIO 308**

Issued to

**DEIF A/S**  
**Skive, Denmark**

is found to comply with  
**DNV GL rules for classification – Ships, offshore units, and high speed and light craft**

**Application :**

**Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV GL.**

<b>Temperature</b>	<b>D</b>
<b>Humidity</b>	<b>B</b>
<b>Vibration</b>	<b>A</b>
<b>EMC</b>	<b>A</b>
<b>Enclosure</b>	<b>A (IP20)</b>

Issued at **Hamburg** on **2018-02-28**

for **DNV GL**

This Certificate is valid until **2023-02-27**.

DNV GL local station: **Aalborg**

Approval Engineer: **Jens Dietrich**

**Joannis Papanuskas**  
**Head of Section**

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid. The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.



## Product description

### CAN bus-based I/O Modules

#### **CIO 116, 16 digital Inputs:**

- Positive or negative common for 2 × 8 inputs
- CAN bus interface
- LEDs to indicate status and input state
- 12/24 V DC supply

#### **CIO 208, 8 relay outputs:**

- 240 V AC or 30 V DC relay contacts
- 8 A relay rating
- CAN bus interface
- LEDs to indicate status and output state
- 12/24 V DC supply

#### **CIO 308, 8 analogue multi-inputs:**

- 8 multi-functional inputs, selectable as
  - Digital input
  - 0(4)-20mA
  - 0-10V
  - RMI
  - PT100
  - PT1000
  - Thermocouple type E, J, K, N, R, S or T
  - Wire break detection
  - CANbus interface
  - LED's to indicate status and input state
  - 12/24V DC supply

## Application/Limitation

The Type Approval covers hardware listed under Product description. When the hardware is used in applications to be classed by DNV GL, documentation for the actual application is to be submitted for approval by the manufacturer of the application system in each case. Reference is made to DNV GL Rules for Ships Pt.4 Ch.9 Control and Monitoring Systems.

### Product certificate

If specified in the Rules, ref. Pt.4 Ch.9 Sec.1, the control and monitoring system in which the above listed hardware is used shall be delivered with a product certificate. For each such delivery the certification test is to be performed at the manufacturer of the application system before the system is shipped to the yard. The test shall be done according to an approved test program. After the certification the clause for application software control will be put into force.

### Clause for application software control

All changes in software are to be recorded as long as the system is in use on board. The records of all changes are to be forwarded to DNV for evaluation and approval. Major changes in the software are to be approved before being installed in the computer.

## Type Approval documentation

Data Sheet/Test Report EPC Test data docs. 4921240524A, 4921240525A, 4921240554A.

Job Id: **262.1-027701-1**  
Certificate No: **TAA00001RS**

### **Tests carried out**

Applicable tests according to DNV GL class guideline CG-0339, November 2016.

### **Marking of product**

Maker, type designation, power supply, serial number.

### **Periodical assessment**

The scope of the periodical assessment is to verify that the conditions stipulated for the type are complied with, and that no alterations are made to the product design or choice of systems, software versions, components and/or materials.

The main elements of the assessment are:

- Ensure that type approved documentation is available
- Inspection of factory samples, selected at random from the production line (where practicable)
- Review of production and inspection routines, including test records from product sample tests and control routines
- Ensuring that systems, software versions, components and/or materials used comply with type approved documents and/or referenced system, software, component and material specifications
- Review of possible changes in design of systems, software versions, components, materials and/or performance, and make sure that such changes do not affect the type approval given
- Ensuring traceability between manufacturer's product type marking and the type approval certificate

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of this certificate.

END OF CERTIFICATE